

Report

www.bsria.co.uk

Frese Valve Tests

Report 18984/2
April 2005

Carried out for: Frese Ltd
Trafalger House
Union Street
Southport
Merseyside
PR9 0QE

Compiled by: P.Stonard

No. of pages: 11 of text

Quality Approved: GREG KING
Head, MicroClimate, Refrigeration & Testing

This report must not be reproduced except in full without the written approval of an executive director of BSRIA. It is only intended to be used within the context described in the text.

SUMMARY

This report details work carried out to determine the ability of Frese Alpha cartridges to meet the manufacturer's specifications in respect of flow control, together with an assessment of any noise generation during operation.

When tested, the ALPHA valves showed control of the flow within +/-5% of the average test flow for each valve.

The average flow for each valve/cartridge combination tested was between 3% and 8% higher than the nominal claimed flow rate. That is, the valves delivered more flow than claimed but maintained control of that flow within +/-5% band.

Fitment of a double swept bend upstream of a Model 1400 valve had no effect on flow control.

Minimum operating pressure differential was within +/-2kPa of the claimed value for nominal flows less 5%.

No discernible noise was detected during the ALPHA tests.

The EVA valve and cartridge combination did not show discernible increases in noise when pressure differential and actuator position were changed to give authority over the cartridge.

Full details of the test programme and results are included within the main body of this report.

CONTENTS

1	INTRODUCTION.....	3
2	ITEMS TESTED	3
3	TEST FACILITY	3
	3.1 Instrumentation.....	5
	3.2 Methodology.....	5
4	Results	6
	4.1 Model 1290.....	6
	4.2 Model 1400.....	7
	4.3 Model 3107.....	8
	4.4 Model 1290 and 1400 plots	9
	4.5 Model 3107 plots.....	10
	4.6 EVA Valve with Model 1400 cartridge.....	11
5	CONCLUSIONS	11
	5.1 Comments/Analysis.....	11
	BSRIA PRODUCTS AND SERVICES	12

APPENDICES

Appendix A	Calibration certificates	12
Appendix B	Manufacturer's literature	27

FIGURES

Figure 1	General view of test rig.....	4
Figure 2	View showing test lengths, flow meter and pressure transducers.....	4
Figure 3	Type 10, model 49-11400 with double bend upstream.....	5

1 INTRODUCTION

This report details work carried out to determine the ability of Frese Alpha cartridges to meet the manufacturer's specifications in respect of flow control, together with an assessment of any noise generation. The work was carried out at Frese armatur A/S, Sorøvej 8, DK-4200, Slagelse during the period 14th-16th March 2005.

The work was conducted by: O Jørgensen for Frese
P Stonard for BSRIA

This report refers to the items tested and no others.

2 ITEMS TESTED

The items tested were selected at random from production stock by P.Stonard and consisted of the following pieces:

Cartridge type	Frese No	Flow (l/hr)	Min ΔP (bar)	Date code
10	49-11290	105	0.10	RO3
10	49-11400 ¹	205	0.12	RO2
30	49-33107	1487	0.13	Q11

1. This item was tested in an ALPHA valve body and an EVA body.

All other cartridges were tested in ALPHA valve bodies.

Each test piece consisted of a cartridge, orifice and retaining clip. A type number and date code was stamped on the orifice and cartridge combination.

3 TEST FACILITY

The test facility was that used by Frese research and development department to validate valve performance. It consisted of a multi pump system fed from a pressurised tank. Test circuits of up to three different pipe sizes could be accommodated on common manifolds and separately valved off to allow flow through individual circuits.

Each circuit in use had a calibrated magnetic flow meter in-line, with a digital readout. Differential pressure was measured by means of three pressure transducers with analogue indicators covering the range 0-6 bar using the integral pressure tappings on the valves (Figures 1 & 2).

Differential pressure was changed by varying the selected pump speed using electronic inverter drives.

Type 10 cartridges were installed in a ¾ BSP pipe size with 500mm straight length upstream and 400mm downstream. A further test was carried out with a double swept bend immediately in front of the 11400 cartridge (Figure 3).


The Type 30 cartridge had 700mm of straight pipe upstream and 500mm downstream on 1¼ BSP pipe.

Figure 1 General view of test rig



Figure 2 View showing test lengths, flow meter and pressure transducers.



Figure 3 Type 10, model 49-11400 with double bend upstream

3.1 INSTRUMENTATION

Instrumentation consisted of the following calibrated items. Calibration certificates can be seen in Appendix A.

Instrument	Serial No.	Date calibrated
Siemens MAG1100/6000 DN25	(1100) 933807T304	19 July 2004
Siemens MAG1100/6000 DN10	(1100) 213604T481	12 August 2004
Siemens transducer 0-600 mbar	NSN Factory No.4	12 August 2004
Siemens transducer 0-3.2 bar	NSJ2871T	13 August 2004
Siemens transducer 0-6.0 bar	N8J7406T	13 August 2004

3.2 METHODOLOGY

The test method consisted of installing each cartridge in turn and raising the pressure in the following increments: 0.1, 0.25, 0.50, 1.0, 2.0 3.0 and 4.0 bar. The flow rate was noted at each pressure. The pressure was then reduced to zero in the same incremental steps to establish the extent of hysteresis.

The pressure was then slowly raised until the flow rate stabilised at the minimum specified value i.e. 5% less than the nominal claimed flow rate, and the pressure noted.

This was repeated for all ALPHA valves and different pipe configurations.

An assessment of noise was made using a stethoscope on the valve body.

In addition, when tested as an EVA valve, pressures were raised in 0.50, 2.0 and 4.0 bar with the motorised actuator full open (10volt). The motorised actuator was then driven to a point where it took authority over the cartridge and the applied pressure difference occurred across the actuator giving a high velocity across the valve seat, with the potential for noise generation.

An assessment of noise was then made using a stethoscope on the valve body.

4 RESULTS

The flow test results are tabulated overleaf, and the data plotted.

A subjective assessment of noise by means of a stethoscope did not detect any extraneous sounds above a slightly increased sound of rushing water at higher pressures and small EVA openings. No whistling or other high-pitched sounds were heard.

No noise at all was evident over the operating range without the use of a stethoscope.

4.1 MODEL 1290

Model:	1290		
DP	Flow		
kPa	l/hr	Min	Max
10	94	107.4	118.7
25	114	107.4	118.7
50	115	107.4	118.7
100	115	107.4	118.7
200	117	107.4	118.7
300	120	107.4	118.7
400	116	107.4	118.7
300	111	107.4	118.7
200	109	107.4	118.7
100	109	107.4	118.7
50	109	107.4	118.7
25	109	107.4	118.7
10	88	107.4	118.7
Nominal	104		
Average	113.1	-5%	5%
Av vs nominal		8.04 %	

Minimum control pressure 12.0kPa to achieve nominal flow value less 5%.

4.2 MODEL 1400

Model:	1400		
DP	Flow		
kPa	l/hr	Min	Max
10	174	200.5	221.6
25	216	200.5	221.6
50	218	200.5	221.6
100	218	200.5	221.6
200	213	200.5	221.6
300	208	200.5	221.6
400	204	200.5	221.6
300	206	200.5	221.6
200	210	200.5	221.6
100	214	200.5	221.6
50	213	200.5	221.6
25	209	200.5	221.6
10	170	201.1	222.3
Nominal	205		
Average	211.7	-5%	5%
Av vs nominal		3.18 %	

With double bends upstream of valve

Model:	1400		
DP	Flow		
kPa	l/hr	Min	Max
10	180	200.5	221.6
25	216	200.5	221.6
50	218	200.5	221.6
100	218	200.5	221.6
200	213	200.5	221.6
300	208	200.5	221.6
400	204	200.5	221.6
300	206	200.5	221.6
200	210	200.5	221.6
100	214	200.5	221.6
50	213	200.5	221.6
25	209	200.5	221.6
10	166	201.1	222.3
Nominal	205		
Average	211.7	-5%	5%
Av vs nominal		3.18 %	

Minimum control pressure 12.5kPa to achieve nominal flow value less 5%

Note that data for the double bend tests was not plotted, as it exactly duplicated that obtained on the previous Model 1400 flow test using straight pipe lengths.


4.3 MODEL 3107

		Model: 3107(2)	
DP	Flow	Min	Max
kPa	l/hr		
10	1207	1469.7	1624.4
25	1554	1469.7	1624.4
50	1576	1469.7	1624.4
100	1570	1469.7	1624.4
200	1550	1469.7	1624.4
300	1542	1469.7	1624.4
400	1543	1469.7	1624.4
300	1530	1469.7	1624.4
200	1530	1469.7	1624.4
100	1545	1469.7	1624.4
50	1554	1469.7	1624.4
25	1523	1469.7	1624.4
10	1200	1469.7	1624.4
Nominal	1487		
Average	1547.00	-5%	5%
Av vs nominal		3.88 %	

Minimum control pressure 14kPa to achieve nominal flow value less 5%.


4.4 MODEL 1290 AND 1400 PLOTS

Flow rate vs pressure differential Type 10 Alpha Cartidge



4.5 MODEL 3107 PLOTS

Flow rate vs pressure difference Type Alpha 30 Cartridge



4.6 EVA VALVE WITH MODEL 1400 CARTRIDGE

Actuator Voltage	Differential Pressure kPa	Flow l/hr	Head pressure Bar
10.0 (cartridge authority)	50	214	0.5
4.0 (actuator authority)	50	81	0.5
10.0 (cartridge authority)	200	209	2.0
4.65 (actuator authority)	200	160	2.0
10.0 (cartridge authority)	400	200	4.0
4.25 (actuator authority)	400	154	4.0

No noise detected during operation.

5 CONCLUSIONS

When tested, the ALPHA valves showed control of the flow within +/-5% of the average test flow for each valve.

The average flow for each valve/cartridge combination tested was between 3% and 8% higher than the nominal claimed flow rate and +/- 5% claimed tolerance. That is, the valves delivered at least 3% more flow than claimed but maintained control of that flow within a +/-5% band.

Fitment of a double bend upstream of a Model 1400 valve had no effect on flow control.

Minimum operating pressure differential was within +/-2kPa of the claimed value for nominal flow less 5%.

No discernible noise was detected during the ALPHA tests.

The EVA valve and cartridge combination did not show discernible increases in noise when pressure differential and actuator position were changed to give authority over the cartridge.

5.1 COMMENTS/ANALYSIS

The valves tested were all new pieces selected from stock. The manufacturer's view was that the average flow would be approximately 3% lower once the cartridge, and more specifically the EPDM diaphragm had been allowed to settle over a longer period than the 2 minutes between readings during the test. This may be the case, but was not included within the test programme.

The Model 1400 and 3107 valves both also maintained flows within a +0%+10% band based on the nominal flow. The Model 1290 fell just outside this band due to the valve hysteresis:- being 'within' with descending pressure, but 'outside' with increasing pressure. This is one of the smallest cartridge/orifice combinations made and consequently +/-5% variation involves a much smaller flow change than for other sizes.

The large format high visibility instrumentation indicators attached to the flow meters resolved to 1 l/hr, which equated to approximately 0.9% at typical flow values used for the Model 1290 tests. Use of the small integral screens on the flow meters, which resolve to 0.1 l/hr may give improved results at lower flows.

BSRIA products and services

BSRIA is a consultancy, test and research organisation helping construction and building services companies to become more efficient and effective.

Our 128-strong team of building services experts can provide the best solutions to the most searching problems ensuring complete confidentiality and individual service at all times.

Working with BSRIA gives you confidence in design, added value in manufacture, competitive advantage in marketing and strategy, profitable construction, effective commissioning and accurate measurement, and efficient building operation and maintenance.

BSRIA membership enables organisations to demonstrate that they are leading the industry through innovation and best practice.

Across all activities	Design	Construct	Operate	Manufacture	Management & Marketing
Instrument solutions Hire Calibration Sales On site services Training Information IBSEDEX – building services abstracts Enquiry service Library Push information (2006) Publications Hard copy On line Training Specialist topics: Whole life costing Introduction to building services Variable speed pumping Facilitation and workshops Relationships Partnering workshops Team building Secretariat support BSETG Co-Construct Constructing Excellence Technical authoring Committee facilitation and support Research management Expert witness work	Design quality and process guidance Design validation Physical modelling Thermal modelling CFD BREEAM assessments Proof of performance testing Standard & bespoke tests <i>(see list under manufacture)</i> Whole life costing Life cycle analysis <i>Consultancy in:</i> Air tightness Cooling of IT rooms Sustainability Grey water Water conservation Renewables Control strategies Specialist enclosure testing Museum display cabinets	Site productivity improvement Measurement Lessons learned database Modular training, feedback and toolbox talks Pocket project handbooks Management KPIs Publications Consultancy and mentoring Training Approval inspections Thermal imaging of fabric Raised floor leakage test Building envelope leakage test (for Part L) Roof inspections Fire stop testing Offsite fabrication Proof of performance and installability <i>(see also design)</i>	Strategic Services Maintenance strategy Business focussed maintenance schedules Building management systems Procurement advice O&M benchmarking Health and safety audit Energy efficiency assessments Building MOTs Energy audits Control system surveys Water and air quality Internal environment monitoring Comfort measurement Sick building syndrome assessment Indoor air quality Pollution monitoring Plant and system investigations Troubleshooting Performance checks Maintenance tasks Site surveys and condition monitoring Plant condition surveys Vibration and sound Non-destructive testing Magnetic field Thermal imaging <i>(failures - electrical plant, damp, underfloor heating, chilled ceilings)</i> Ultrasonic pipe work testing Power quality Electrical surveys Magnetic field survey Lighting level and control survey <i>For due diligence and legal compliance</i>	Testing and certification to recognised standards Air cleaners Air filters Air handling units Air heaters Atomising oil nozzles Axial fans Blockwork porosity Boilers Chilled ceilings Chillers Coolers and condensers Displacement ventilation Ductwork Expansion vessels Fan coils Fire valves Flue lining systems Fume cupboards Louvres Metal flues, chimneys, fittings and terminals Radiators Refrigeration equipment Smoke and fume extraction fans Testing thermal performance, emissions, EMC, MTBF, noise Testing to client requirements Energy labelling Product failure analysis Standards development Writing Evaluating Publishing Design of test facilities Support for new product development	Business strategy Strategic planning Bespoke assignments, or one day consultancies Procurement advice Bid support Business Performance Forum Supply chain management Partnering workshops Marketing strategy - <i>confidential studies on:</i> Market entry Acquisition New product development Technical appraisal Distributions and pricing strategy Market research - size and structure of markets <i>Heating, air conditioning, plumbing and sanitaryware, controls, renewables, structured cabling, FM and contracting</i> Confidential studies Published reports Global studies annually In depth studies Statistics clubs Attitudinal studies Customer research Customer satisfaction Product acceptability Understanding clients' needs <i>Market research techniques used:</i> Focus groups Personal interview Desk research Telephone, fax and web surveys Questionnaire design