

Certificate

independent certification of your products & services

This is to certify that the following product or service has met the requirements detailed below

**National Health Service Model engineering specification D 08
Thermostatic mixing valves (Healthcare premises)**

**FRESE A/S
SERIES 160**

Approved for the following designations:

HP-S: High Pressure Shower
HP-W: High Pressure Washbasin
LP-B: Low Pressure Bidet
LP-S: Low Pressure Shower
LP-W: Low Pressure Washbasin

Accessories included as part of the approval:
Integral Check Valves, In-line strainers.



assessor



director

25/09/2002

issue date

25/09/2007

expiry date



ETC/185/0902

certificate number

